

The safety check function should only be used by authorized engineers.

Required information for service purposes

Location: _____

Burner data: _____

Burner Management System LMV5x

	ASN	Production date	SW version
Burner control			
Load controller			
AZL			
Air actuator			
Gas actuator			
Oil actuator			
Aux. actuator			

Lockout history


No.	Date	Time	Code	Diag.-Code	Fault-Phase	Start-No.	Load	Fuel	Discription
1									
2									
3									
4									
5									
6									
7									
8									
9									

© Siemens Building Technologies Ltd.

User Guide

User level AZL (LMV51...)

Legend for User Guide and AZL



For language option, select:

Params&Display => Access w-out PW => AZL => Language


Display

Display Normal Operation




Depending on the burner sequence, other displays will be shown.

Display Lockout or Fault



When display changes, press **Enter** to maintain the display.


Menu



1 Lockout history example


```

8 16.10.01 09:36
C:30 0:00 P:40
START NO: 70
LOAD: 20 GAS
    
```



When display changes, press to maintain the display.

< SELECT > Select fault history



Manual Operation Set Load Autom/Manual/Off

